

RESOLUTION NO. 2021-73

**A RESOLUTION OF RADNOR TOWNSHIP, DELAWARE COUNTY,
PENNSYLVANIA, AUTHORIZING EMERGENCY REPLACEMENT OF THE
CONTROLLER AT THE KING OF PRUSSIA PUMP STATION IN THE
AMOUNT OF \$15,240**

WHEREAS, the Township is responsible for the maintenance, and repairs to the sanitary sewer mains and pumping station's

WHEREAS, the Township's King of Prussia Pumping Station's LC-150 Controller has lost all visual controls

WHEREAS, the LC-150 Controller tells the sewer pump when to operate and for how long

WHEREAS, the LC-150 Controller is an integral component of the Pump Station Operation


WHEREAS, the Township Manager has provided emergency authorization to order and replace the Controller at the King of Prussia Pump Station


WHEREAS, Municipal Maintenance and provided a quote in the amount of \$15,240 for the removal and replacement of a new controller in the amount of \$15,240

NOW, THEREFORE, be it **RESOLVED** the Board of Commissioners of Radnor Township does hereby authorize emergency replacement of the LC-150 Controller at the King of Prussia Sewer Pump Station in the amount of \$15,240.

SO RESOLVED this 14th day of June, A.D., 2021

RADNOR TOWNSHIP

By: 
Name: Jack Larkin
Title: President

ATTEST: 
William M. White
Township Manager/Secretary