# RESOLUTION NO. 2023- <u>Al</u>

A RESOLUTION OF THE BOARD OF COMMISSIONERS OF RADNOR TOWNSHIP, DELAWARE COUNTY, PENNSYLVANIA, APPROVING THE FINAL SUBDIVISION AND LAND DEVELOPMENT PLAN FOR ST. HONORE' HOLDING, LP CONSISTING OF FOURTEEN (14) NEW SINGLE-FAMILY DWELLING LOTS AT EAGLE AND STRAFFORD ROAD.

WHEREAS, the Radnor Township Planning Commission and Delaware County Planning Commission have reviewed the Final Subdivision and Land Development Plan for St. Honoré Holding, LP ("Applicant"); and

WHEREAS, the Board of Commissioners granted preliminary Subdivision and Land Development Plan approval pursuant to Resolution 2023-04; and

WHEREAS, the Board of Commissioners now intends to approve the Final Subdivision and Land Development Plan for the property located at Eagle and Strafford Road in the Township.

**NOW, THEREFORE,** be it hereby **RESOLVED** that: the Board of Commissioners approves the Final Subdivision and Land Development Plan prepared by Apex Engineering Group, dated August 5, 2022, last revised January 4, 2023, subject to the following final plan approval conditions:

- 1. Compliance with the Gannett Fleming Review Letter dated February 15, 2023, a copy of which attached hereto and incorporated herein as Exhibit "A".
- 2. Compliance with the Gilmore & Associates, Inc. review letter dated January 11, 2023, a copy of which is attached hereto and incorporated herein as Exhibit "B".
- 3. Compliance with the Preliminary Subdivision and Land Development Approval Resolution 2023-04, a copy of which is attached hereto and incorporated herein as Exhibit "C".
- 4. Compliance with all applicable Township Ordinances with respect to sewage, stormwater management, zoning and building, and compliance with all county, state and federal rules, regulations and statutes including approval by the Pennsylvania Department of Environmental Protection for required planning modules for the property. No work shall commence on the project until such time as all outstanding approvals have been received, and development and financial security agreements have been established with the Township.
- 5. The Applicant shall execute development and financial security agreements in a form and manner to be approved by the Township Solicitor.

- 6. The Applicant shall pay the required Park and Recreation Fee in the amount of Three Thousand Three Hundred and Seven (\$3,307.00) Dollars for each of the fourteen (14) proposed new dwelling units.
- 7. All subdivision and land development ordinance waivers previously approved pursuant to the Preliminary Subdivision Land Development Approval Resolution are reapproved under this Final Plan Approval Resolution.

SO RESOLVED, at a duly convened meeting of the Board of Commissions of Radnor Township on this 13 day of Mach 2023.

RADNOR TOWNSHIP

Name: Moira Mulroney

Title: President

William White, Township Manager

ATTEST:



Valley Forge Corporate Center 1010 Adams Avenue Audubon, PA 19403 P 610.650.8101 | F 610.650.8190

gannettfleming.com

Date: February 15, 2023

To: Steve Norcini, PE Township Engineer

From: Roger Phillips, PE

cc: Kevin W. Kochanski, RLA, CZO - Director of Community Development

John Rice, Esq. - Grim, Biehn, and Thatcher

Damon Drummond, PE - Gilmore & Associates, Inc.

Patricia Sherwin - Radnor Township Engineering Department

RE: St Honore - Eagle/Strafford Road

Date Accepted:

02/06/2023

90 Day Review:


05/07/2023

Gannett Fleming, Inc. has completed a review of the Final Land Development plans for the above referenced project for compliance with the Radnor Township Code. The Plans were reviewed for conformance with Subdivision and Land Development, Zoning and other applicable codes of the Township of Radnor.

The applicant is proposing to subdivide the property into fourteen lots and construct fourteen single-family homes. This project is located within the R-4 zoning district of the Township.

The applicant has indicated on the plans that the following waivers are being requested:

- §255-20-B(1)(N) To allow for information depicted on the vicinity plan to be accepted for depicting infrastructure and other features within 500 feet of subject site.
- §255-27-C(1) To not install curb along Strafford Avenue due to prevailing existing conditions and to avoid conflicts with exiting utilities.
- §255-27-C(1) To the extent necessary to not provide the required half width cartway along the site frontage of Eagle Road and Strafford Avenue due to prevailing existing conditions and to avoid conflicts with exiting utilities.
- §255-37 To not install sidewalk north of the proposed Rue St. Honore along Eagle Road to lessens impact to mature vegetation on adjacent property.
- §255-28.B To allow a sight distance on a major collector road to meet PA DOT requirements as per PA Title 67 §441.8.





# Final Land Development Plan - St. Honore

Plans Prepared By: A

Apex Engineering Group

Dated:

08/05/2022, last revised 01/04/2023

# Sewage Facilities Planning

1. Final plan approval will not be granted until Planning Approval or a Planning Exemption is received from the PA DEP. To the best of our knowledge this has not yet been submitted to the PA DEP.

# Subdivision and Land Development

- 1. §255-20-B(1)(n) Existing principal buildings (and their respective uses) and driveways on the adjacent peripheral strip. Sewer lines, storm drains, culverts, bridges, utility easements, quarries, railroads and other significant man-made features within 500 feet of and within the site (this includes properties across streets) must be shown on the plans. The applicant has requested a partial waiver.
- 2. §255-27.C(1) Local streets (Strafford Ave) must have a right of way of 60 feet, a cartway of 28 feet and curbing and sidewalks. The applicant is requesting a waiver to not install curbing along Strafford Avenue.
- 3. §255-27.C(1) Cul-de-sacs must have a right of way of 60 feet, a cartway of 28 feet and curbing and sidewalks. The applicant is requesting a waiver from this requirement to not install sidewalk north of the proposed road.
- 4. §255-28.B The applicant has requested a waiver to allow site distance on a major collector to meet PA DOT requirements.
- 5. §255-37.C Sidewalks and public paths shall be located within a public right-of-way, public easement or a common open space area. The applicant has requested a waiver of §255-37 to not install sidewalk North of the proposed road along Eagle Road to lessen the impact to mature vegetation on adjacent property.
- 6. §255-40.C(2) Access and circulation for fire-fighting and other emergency equipment, moving vans, fuel trucks, garbage collection, deliveries and snow removal shall be planned for efficient operation and convenience. The applicant has indicated that the snow removal area is anticipated to be plowed to either side of the cul-de-sac and the area between lot 7 and 8. The vehicles utilized in the turning movements must be dimensioned on the plans.



- 7. §255-43.1.B(1) For all residential subdivisions or land developments involving a total of four or more lots and/or dwelling units, a minimum of 1,440 square feet or suitable park and recreation land shall be provided per dwelling unit within such subdivision/land development, unless the developer agrees to a fee in lieu of \$3,307 per dwelling unit (existing or proposed).
- 8. §255-54.B The central water system should be designed with adequate capacity and appropriately spaced fire hydrants for fire-fighting purposes pursuant to the specification of the National Fire Protection Association. Review and approval by the Township Engineer and the Township Fire Marshall shall be required in order to ensure that adequate fire protection is provided.

#### Stormwater

1. Final approval of the stormwater management plan will be required as part of the Grading Permit process. Any revisions to the size or location of the individual structures or other features will be addressed at this time.

The applicant appeared before the Planning Commission on February 6, 2023. The Planning Commission made a motion to recommend final approval to the Board of Commissioners.

If you have any questions or require any additional information, please contact me.

Very truly yours,

GANNETT FLEMING, INC.

Roger A. Phillips, P.E. Senior Project Manager



## GILMORE & ASSOCIATES, INC.

ENGINEERING & CONSULTING SERVICES

#### **MEMORANDUM**

Date:

January 11, 2023

To:

Steve Norcini, P.E.

From:

Damon Drummond, P.E., PTOE

cc:

Roger Philips, P.E. Leslie Bogdnoff, P.E.

Reference:

St. Honoré Holding LP

Preliminary/Final Land Development Radnor Township, Delaware County

Transportation Review 5

G&A #20-10016-01

Our transportation department has completed a review for the Preliminary Subdivision and Land Development plans prepared for St. Honoré Holding LP. We offer the following comments for your consideration:

#### A. PROJECT DESCRIPTION

The Applicant, St. Honoré Holding LP, is proposing to subdivide the property and construct fourteen (14) single-family detached dwelling units and related improvements on each lot. Ten (10) of the homes are proposed to have access to Eagle Road via a proposed cul-desac and four (4) of the homes are proposed to have direct access to Strafford Avenue.

## B. <u>DOCUMENTS REVIEWED</u>

- 1. Final Subdivision and Land Development Plans prepared by APEX Design & Engineering Group, LLC, prepared for St. Honoré Holding LP, consisting of 21 sheets, dated August 5, 2022 and last revised January 4, 2023.
- 2. Response Letter prepared by APEX Design & Engineering Group, LLC, dated January 4, 2023.

### C. WAIVERS REQUESTED

- 1. §255-20.B(1)(N) To allow information depicted on the vicinity plan to be accepted for depicting infrastructure and other features within 500 feet of the subject site.
- 2. §255-27.C(1) From installing curbing along Strafford Avenue due to prevailing existing conditions and to avoid conflicts with existing utilities.



- 3. §255-27.C(1) To not provide the required half width cartway along the site frontage of Eagle Road and Strafford Avenue due to prevailing existing conditions and to avoid conflicts with existing utilities.
- 4. §255-27.C(1) & §255-37 To not install sidewalk north of the proposed road and along Eagle Road to lessen impact to mature vegetation on the adjacent property.
- 5. §255-28.B To allow a sight distance on a major collector road to meet PaDOT requirements as per PA title 67 §441.8.

# D. SUBDIVISION AND LAND DEVELOPMENT ORDINANCE COMMENTS

- 1. §255-27.C(2) Additional cartway widths may be required by the Board of Commissioners.
  - a. As previously stated, Eagle Road is classified as a major collector with a required 48 foot cartway width. The existing cartway width along the site frontage is 18 feet. A 24-foot half-width cartway is required along the site frontage in accordance with §255-27.C(1). We acknowledge the Applicant has requested a waiver for this comment.
  - b. Strafford Avenue is classified as a local street with a required 28-foot cartway width. The existing cartway width along the site frontage is 24 feet. A 14-foot half-width cartway is required along the site frontage in accordance with §255-27.C(1).We acknowledge the Applicant has requested a waiver from this requirement.

## E. GENERAL TRANSPORTATION COMMENTS:

 The street name will be subject to the review and approval of the Township, Delaware County and the US Postal Service. Comment has been acknowledged by the Applicant.

#### RESOLUTION NO. 2023-04

A RESOLUTION OF THE BOARD OF COMMISSIONERS OF RADNOR TOWNSHIP, DELAWARE COUNTY, PENNSYLVANIA, APPROVING THE PRELIMINARY SUBDIVISION AND LAND DEVELOPMENT PLAN FOR ST. HONORE' HOLDING, LP CONSISTING OF FOURTEEN (14) NEW SINGLE-FAMILY DWELLING LOTS AT EAGLE AND STRAFFORD ROAD.

WHEREAS, the Radnor Township Planning Commission and Delaware County Planning Commission has reviewed the Subdivision and Land Development Plan for St. Honoré Holding, LP (Applicant"); and

WHEREAS, the Board of Commissioners now intends to approve the Preliminary Subdivision and Land Development Plan for the property located at Eagle and Strafford Road in the Township.

**NOW, THEREFORE,** be it hereby **RESOLVED** that: the Board of Commissioners approves the Preliminary Subdivision and Land Development Plans prepared by Apex Engineering Group, dated August 5, 2022, last revised November 30, 2022, subject to the following preliminary plan approval conditions:

- 1. Compliance with the Gannett Fleming Review Letter dated December 7, 2022, a copy of which attached hereto and incorporated herein as Exhibit "A".
- 2. Compliance with the Gilmore & Associates, Inc. review letter dated December 9, 2022, a copy of which is attached hereto and incorporated herein as Exhibit "B".
- 3. Compliance with all applicable Township Ordinance with respect to sewage, stormwater management, zoning and building, and compliance with all county, state and federal rules, regulations and statutes including approval by the Pennsylvania Department of Environmental Protection for required planning modules for the property.
- 4. The Applicant shall execute development and financial security agreements in a form and manner to be approved by the Township Solicitor.
- 5. The Applicant shall pay the required Park and Recreation Fee in the amount of Three Thousand Three Hundred and Seven (\$3,307.00) Dollars for each of the fourteen (14) proposed new dwelling units.
- 6. Thirty days after approval of this Resolution, the Applicant shall withdraw its nine lot subdivision plan, Application 206965.

In addition to the foregoing conditions of preliminary subdivision and land development approval, the following subdivision and land development ordinance waivers are resolved as follows:



A.	Section 255-20. B (1)(n) regarding existing features within five hundred (500) feet of site. APPROVED X DENIED
B.	Section 255-27 C. (1) and 277-37 for a partial waiver to the sidewalk installation requirement along a portion of Eagle Road and north of the new cul-de-sac road.
	APPROVEDX
C.	Section 255-27 as to curbing and half width cartway along Strafford Avenue and as to half width cart width along Eagle Road
	APPROVED_X
D.	Section 255-28 B. to permit sight distance along a major collector to comply with PennDOT requirements under Pa. Title 67 441.8
	APPROVED X DENIED
SO RESOLVED, at a duly convened meeting of the Board of Commissions of Radnor Township on this 3 <sup>rd</sup> day of January 2023.	
	RADNOR TOWNSHIP
	North Muleene
	Name: Moîra Mulroney Title: President
ATTEST:  William W	hite, Township Manager