



FOOD ESTABLISHMENT INSPECTION REPORT

RADNOR TOWNSHIP
301 Iven Avenue - Wayne, PA 19087
Phone (610) 688-5600

FOOD ESTABLISHMENT INFORMATION

<u>FE NAME</u>					<u>LICENSE</u>
TERESA'S CAFE					FE00000772
<u>ADDRESS</u>				<u>INSP. TYPE</u>	<u>INSP. NUMBER</u>
124 N WAYNE	AVE WAYNE	PA 19087-	FEI	6343	
<u>MANAGER NAME</u>	<u>INSP. DATE</u>	<u>TIME IN</u>	<u>TIME OUT</u>	<u>PURPOSE</u>	
MICHAEL ELLIS	11/17/2015	7:00 PM	8:15 PM	FIRE IN KITCHEN	
	<u>OVERALL COMPLIANCE</u>	<u>RISK CATEGORY</u>			
	OUT				

OBSERVATIONS AND CORRECTIVE ACTIONS

VIOLATIONS CITED IN THIS REPORT MUST BE CORRECTED WITHIN THE TIME FRAMES BELOW.

COMPLIANCE STATUS: OUT = not in compliance, N/O = not observed, N/A = not applicable, C = corrected on site, R = repeated

<u>COMP STAT</u>	<u>VIOLATION OF CODE</u> <u>COMMENTS</u>	<u>NEW/OLD VIOLATION</u> <u>CORRECT BY DATE</u>
0.	No PA Food Code Violations	
OUT	0. No PA Food Code Violations SEE NARRATIVE	

FOODBORNE ILLNESS RISK FACTORS AND PUBLIC HEALTH INTERVENTIONS

COLD / HOT HOLDING AND TEMPERATURES

WAREWASHING FACILITIES

REMARKS

AS A RESULT OF A FIRE ON THE NORTH SIDE OF THE RESTAURANT THIS SIDE OF THE RESTAURANT IS PLACED OUT OF SERVICE BY THE FIRE CODE OFFICIAL DUE TO THE LACK OF FIRE PROTECTION ON THE NORTH SIDE OF THE BUSINESS. *** THE SOUTH SIDE OF THE BUSINESS WAS PERMITTED TO OPERATE WITH THE FOLLOWING CONDITIONS: * 2 OF 3 DOORWAYS THAT COMMUNICATE BETWEEN THE TWO SIDES MUST BE TAPED OFF TO PREVENT CROSS OVER CUSTOMER TRAFFIC AND CONTAMINATION OF FOOD. * MUST MAINTAIN A CLEAR AND UNOBSTRUCTED PATH TO THE REAR EXIT DOOR TO THE EXTERIOR ON THE SOUTH SIDE OF THE BUSINESS. * HAVE THE SOUTH SIDE KITCHEN HOOD SERVICED TO ENSURE THAT IT IS SAFE & CLEAN. * CLEAN THE GRILL ON THE SOUTH SIDE OF THE BUSINESS. * CLEAN THE FLOOR UNDER THE GRILL, FAT FRYER AND OTHER EQUIPMENT ON THE SOUTH SIDE. * THE WATER FILTER LEAKS AND MUST BE CORRECTED. * REMOVE THE DUNNAGE RACKS FROM IN FRONT OF THE WATER FILTER AND HAND WASH SINKS. * THE NORTH SIDE OF THE BUSINESS SHALL NOT OPEN UNTIL APPROVAL IS GIVEN BY THE FIRE CODE OFFICIAL AND HEALTH OFFICER. 11/17/15 - STAFF HAVE BEEN AGGRESSIVELY CLEANING IN AN EFFORT TO GET RE-OPENED. *

SIGNATURES

Person in Charge (Signature): _____ 11/19/2015

Inspector (Signature): Larry Taltoan 11/19/2015

Larry Taltoan