

PROJECT	<u>Villanova University - WLA Parking Lot</u>	PROJECT NO.	<u>056756.249</u>
CLIENT	<u>Radnor Twsp.</u>	DATE	<u>01/13/2016</u>

Arrival Time	<u>8:00a</u>	Weather:	<input checked="" type="checkbox"/> Clear	<input type="checkbox"/> Overcast	<input type="checkbox"/> Rain	<input type="checkbox"/> Hot	<input type="checkbox"/> Warm	<input type="checkbox"/> Cool	<input checked="" type="checkbox"/> Cold
Departure Time	<u>4:00p</u>	Site Condition:	<input type="checkbox"/> Clear	<input type="checkbox"/> Muddy	<input type="checkbox"/> Dusty	<input type="checkbox"/> Wet	<input checked="" type="checkbox"/> Snow	<input checked="" type="checkbox"/> Ice	<input type="checkbox"/> Foggy
Total Hours	<u>8.0</u>	Temp Range:	<u>21°F to 25°F</u>						

CONTRACTOR <u>Torcon</u>	SUBCONTRACTOR(S) <u>JJD, HB Frazier, Mayfield Gardens, Rockwell Associates</u>
---------------------------------	---

LABOR FORCE	WORK PERFORMED
Superintendent <u>1</u>	1.) JJD installed the 18" HDPE Flared End Section labeled as (FES-101) that feeds into the proposed "Rain Garden". a.) They then installed the new precast storm inlet labeled as (I-102B). b.) They then installed 46' of 18" HDPE to connect the two structures together. 2.) Mayfield Gardens continued installing trees and shrubs in the "Buffer Zone" area with Bob (Rockwell Associates) observing all means and methods including grading. 3.) JJD extended the subgrade for the proposed road that runs along the "Buffer Zone" area. 4.) HB Frazier began to pull string lines through the installed conduit running between the electrical handholes to prepare for the wire installation. 5.) HB Frazier began excavation for the proposed "Communication Ductbank" directly in front of Moriarty Hall. 6.) HB Frazier excavated out of the electric handhole located (SE of proposed MH-119) in the proposed island area for the entrance to be installed on the East side of Farrell Hall. Rebar and spacers were installed before concrete encasing the 4-4" PVC conduit.
Foreman <u>3</u>	
Operators <u>6</u>	
Laborers <u>9</u>	
Drivers <u>1</u>	
EQUIPMENT USED:	
Excavator <u>6</u>	
FEL <u>1</u>	
Dump Truck <u>3</u>	
Backhoe <u>2</u>	
Hoe Pac <u>2</u>	
Vibratory Roller <u>2</u>	
Motorized Tamper <u>3*</u>	
Large Roller <u>1</u>	
Bulldozer <u>2</u>	
Lull <u>1</u>	

SKETCH	COMMENTS
	1.) Under Equipment Used I have noted three (3) items as Other. 1-Stump Grinder, 1-Dingo, and 1-Skid Steer.
	INSPECTOR: <u>Jason Thompson - Gannett Fleming</u>

