

<b>PROJECT</b> Villanova University - Pike Field Garage	<b>PROJECT NO.</b> 056756.256
<b>CLIENT</b> Radnor Twsp.	<b>DATE</b> 04/29/2016

Arrival Time 12:00p	Weather: <input type="checkbox"/> Clear <input checked="" type="checkbox"/> Overcast <input type="checkbox"/> Rain <input type="checkbox"/> Hot <input type="checkbox"/> Warm <input checked="" type="checkbox"/> Cool <input type="checkbox"/> Cold
Departure Time 12:30p	Site Condition: <input type="checkbox"/> Clear <input type="checkbox"/> Muddy <input type="checkbox"/> Dusty <input checked="" type="checkbox"/> Wet <input type="checkbox"/> Snow <input type="checkbox"/> Ice <input type="checkbox"/> Foggy
Total Hours 0.5	Temp Range: 54°F to 43°F

<b>CONTRACTOR</b> Torcon	<b>SUBCONTRACTOR(S)</b> JJD, Cook Drilling
--------------------------	--

LABOR FORCE	WORK PERFORMED
Superintendent 1 Foreman 0 Operators 1 Laborers 1 Drivers 0	1.) I walked the entire site to check on all installed E&S controls which all appear functional at this time. 2.) Cook Drilling continues to drill for the proposed caissons. 3.) Multiple concrete trucks were onsite today for the Caisson installation. Cook Drilling had two (2) laborers tending the Construction Entrance helping to clean the tires and keep the roads clear of any dirt and/or mud.
<b>EQUIPMENT USED:</b>	
Excavator 1 FEL 1 Dump Truck 10 Backhoe 1 Hoe Pac _____ Vibratory Roller _____ Motorized Tamper _____ Other _____ Large Roller _____ Bulldozer _____ Lull _____	

SKETCH	COMMENTS
<b>INSPECTOR:</b> Jason Thompson - Gannett Fleming	