

INSPECTOR'S DAILY REPORT

PROJECT	Villanova	University - Pike Field Garage		PROJECT NO. 056756.256			
CLIENT	Radnor To	ownship		DATE 09/16/2016			
Arrival Time Departure Time Total Hours	9:30 2:30 4hrs	Weather:					
CONTRACTOR Torcon			SUBCONTRACTOR(S) JJD, Molly, Kehoe, High/Sautter, Roma				
LABOR FORCE		WORK PERFORMED					
Superintendent 1 Foreman 1 Operators 4 Laborers 6 Drivers 2 EQUIPMENT USED: Excavator 2 FEL 1 Dump Truck 2 Backhoe 1 Hoe Pac Vibratory Roller Motorized Tamper 2 Other		 Arrived onsite for required construction observation services and general site inspections. High/Sautter onsite continuing parking garage construction. Water truck onsite for dust control. Sweeper truck onsite cleaning roadways and parking areas of any site dirt and debris. JJD onsite excavating for storm water management system MH-JF10 in the southwest corner of site adjacent to proposed parking garage. JJD is sealing up the 18" storm pipes entering and exiting MH-311 aswell as the 18" storm pipe entering the Vortechs vault. JJD is continuing 18" storm sewer out of MH-209 into MH-210. Pipe penetrations were sealed up and the run was backfilled and tamped per the approved site plans. 					
	Sl	KETCH		COMMENTS			
			INSP	PECTOR: ndon Shirey - Gannett Fleming			