

PROJECT	<u>Villanova University - Church Bridge</u>	PROJECT NO.	<u>056756.272</u>
CLIENT	<u>Radnor Township</u>	DATE	<u>04/01/2017</u>

Arrival Time	<u>1:00p</u>	Weather:	<input type="checkbox"/> Clear	<input checked="" type="checkbox"/> Overcast	<input checked="" type="checkbox"/> Rain	<input type="checkbox"/> Hot	<input type="checkbox"/> Warm	<input type="checkbox"/> Cool	<input checked="" type="checkbox"/> Cold
Departure Time	<u>2:00p</u>	Site Condition:	<input type="checkbox"/> Clear	<input checked="" type="checkbox"/> Muddy	<input type="checkbox"/> Dusty	<input checked="" type="checkbox"/> Wet	<input type="checkbox"/> Snow	<input type="checkbox"/> Ice	<input type="checkbox"/> Foggy
Total Hours	<u>1 hrs</u>	Temp Range:	<u>35°F to 50°F</u>						

CONTRACTOR <u>Torcon, Inc.</u>	SUBCONTRACTOR(S) <u>Mayfield Site Cont. Inc.</u>
---------------------------------------	---

LABOR FORCE	WORK PERFORMED
Superintendent <u>1</u> Foreman <u>1</u> Operators <u>1</u> Laborers <u>3</u> Drivers _____	Mayfield Site Construction subcontracted Ram-T Landscape Contractors to install the erosion and sediment controls for the area in front of the church. Silt socks were filled to about 12 inches in diameter and set in place in general accordance with the grading plans. The contractor installed the silt socks covering a wider area at the southern perimeter and adjusted the silt socks up-hill to better match the contours of the grounds. Overall the E&S controls as they were installed are set up to handle more area coverage and material.
EQUIPMENT USED:	
Excavator _____ FEL _____ Dump Truck _____ Backhoe _____ Hoe Pac _____ Vibratory Roller _____ Motorized Tamper _____ Other _____ _____ _____ _____	

SKETCH	COMMENTS
INSPECTOR: <u>William Wood-Jenkins - Gannett Fleming</u>	