

<b>PROJECT</b> Villanova University - Pike Field Garage	<b>PROJECT NO.</b> 056756.256
<b>CLIENT</b> Radnor Township	<b>DATE</b> 02/08/2017

Arrival Time <u>2:00p</u>	Weather: <input checked="" type="checkbox"/> Clear <input type="checkbox"/> Overcast <input type="checkbox"/> Rain <input type="checkbox"/> Hot <input checked="" type="checkbox"/> Warm <input type="checkbox"/> Cool <input type="checkbox"/> Cold
Departure Time <u>3:00p</u>	Site Condition: <input checked="" type="checkbox"/> Clear <input type="checkbox"/> Muddy <input type="checkbox"/> Dusty <input type="checkbox"/> Wet <input type="checkbox"/> Snow <input type="checkbox"/> Ice <input type="checkbox"/> Foggy
Total Hours <u>1 hr</u>	Temp Range: <u>42°F</u> to <u>65°F</u>

<b>CONTRACTOR</b> Torcon, Inc.	<b>SUBCONTRACTOR(S)</b> J.J.Dougherty, Tristate Fence Co.
--------------------------------	-----------------------------------------------------------

LABOR FORCE	WORK PERFORMED
Superintendent <u>2</u> Foreman <u>1</u> Operators _____ Laborers <u>2</u> Drivers _____	Onsite to review the safety fence installation along the southern side of the parking garage site against the SEPTA rail line. Tristate Fence Co. for John J. Dougherty and Sons, Inc. began work on the safety fence; auguring post holes about 12' appart and setting posts between the steps leading up to the SEPTA stop and the modular block retaining wall south of the garage. Posts are comprise of 10' long 5" diameter treated pine as per the project landscape drawing details.
<b>EQUIPMENT USED:</b>	
Excavator _____ FEL _____ Dump Truck _____ Backhoe _____ Hoe Pac _____ Vibratory Roller _____ Motorized Tamper _____ Other <u>1</u> _____ _____ _____	

SKETCH	COMMENTS
	<b>INSPECTOR:</b> William Wood-Jenkins - Gannett Fleming